



Project: 1216 Arcola Ave

## Analytical Results

Project Number: [none]  
Client Name: YESHIVA GREATER WASH  
Project Manager: Shim Kurtz

Reported:  
13-Aug-18 17:03

### Method: EPA 200.8

Sample Name	ECL #	Sample Desc	Analyte	Result	Units	Analyzed Date	Analyst
YGW A KS1 104	E055108-01		Lead	< 1.0	ug/L	8/8/2018 10:09:49AM	MAP
YGW A KS2 104	E055108-02		Lead	< 1.0	ug/L	8/8/2018 10:12:37AM	MAP
YGW A KS3 104	E055108-03		Lead	< 1.0	ug/L	8/8/2018 10:15:26AM	MAP

Stephen Shelley, Laboratory Director

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*



Project: 1216 Arcola Ave


## Analytical Results

Project Number: [none]  
Client Name: YESHIVA GREATER WASH  
Project Manager: Shim Kurtz

Reported:  
13-Aug-18 17:03

## Notes and Definitions

DET Analyte DETECTED  
ND Analyte NOT DETECTED at or above the reporting limit  
NR Not Reported  
dry Sample results reported on a dry weight basis  
RPD Relative Percent Difference



Stephen Shelley, Laboratory Director

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

55108

School Name	School Outlet ID/Floor Plan ID	Building Address	Date Water Last Used	Time Water Last Used	Date Sample Collected	Time Sample Collected
Yeshiva of Greater Washington	YGW A KS1 104	1216 Arcola Ave. Silver Spring, MD. 20902	8/5/2018	8: PM	8/6/2018	7:30:00 AM
Yeshiva of Greater Washington	YGW A KS2 104	1216 Arcola Ave. Silver Spring, MD. 20902	8/5/2018	8: PM	8/6/2018	7:30:00 AM
Yeshiva of Greater Washington	YGW A KS3 104	1216 Arcola Ave. Silver Spring, MD. 20902	8/5/2018	8: PM	8/6/2018	7:30:00 AM

Fed Ex 8/2/18 @ 11da  
N